IAPMO RESEARCH AND TESTING, INC.

4755 E. Philadelphia Street, Ontario, CA 91761 • Phone (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org

CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body in which its product certification system includes inspection and testing of samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and/or warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued To:

SKYWELL, LLC

1641 20TH ST. SANTA MONICA CA 90404 UNITED STATES

Product:

Ultraviolet Microbiological Water Treatment System

Products are certified to the following standard(s)

NSF/ANSI 55-2024

File Number: W-10486

Effective Date: January 2024

Void After: January 2029*

Chairman, Product Certification Committee

Chief Technical Service Officer

*This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Issued To: SKYWELL, LLC

File Number: W-10486

Product: Ultraviolet Microbiological Water Treatment System

Effective Date: January 2024

Void After: January 2029

This certificate is not evidence of current listing.To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

A permanent plate or label shall be affixed in a readily accessible location on the system and shall contain, at a minimum, the following information:
model number and class designation;
name and address of manufacturer;
maximum working pressure in kPa (psig);
maximum operating temperature in degrees C (degrees F);
model number of UV lamps;
maximum operating feed water temperature in degrees C (degrees F);
applicable warning signs;
a use limitations statement: “See instruction manual for use conditions”;
maximum flow rate in L/min (gpm or gpd);
operational voltage, amperage, and Hertz of the system;
required replacement intervals of ultraviolet lamp(s);
"NSF/ANSI 55".

Characteristics:

The point-of-use and point-of-entry systems addressed by this Standard are designed to be used for the reduction of microbiological organisms (bacteria, virus, and cyst) that may be present in drinking water of unknown quality which are considered health hazards. This standard covers systems which use ultraviolet (UV) radiation within the range of 240 nm to 300 nm inclusive.

Class A systems are designed to be used for treating microbiologically unsafe water, but do not reduce chemical or inert particulate contaminants. Systems covered in this standard are designed to inactivate microorganisms, including bacteria, virus and cysts, from water.

Class B systems are designed to be used for supplemental bactericidal treatment for the inactivation of nonpathogenic nuisance microorganisms that may be present in drinking water considered to be microbiologically safe and of known quality. Class B systems are not to be used on water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system.

To be used and installed in accordance with the manufacturer's instructions.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Models

Product Type: Air to Water Filtration

Products in this section may use the following mark: # added for display of logo

Model Number	Replacement Component	Flow Rate (GPM)	Capacity (Gallons)	Reduction Claims
5T1.5	105371, 105321, 105341	0.5	150	Class A Disinfection